



- NOTES:**
1. THE GENERAL CONTRACTOR SHALL FINISH AND INSTALL A 3/4" X 4" X 4'-0" TELEPHONE AND DATA RISER SYSTEM WITH TELEPHONE PLYWOOD BACKBOARD FOR TELEPHONE EQUIPMENT.
 2. THE GENERAL CONTRACTOR SHALL FINISH AND INSTALL A 3/4" X 4'-0" X 4'-0" TELEVISION RISER SYSTEM WITH TELEVISION PLYWOOD BACKBOARD FOR TELEVISION EQUIPMENT.
 3. THE ELECTRICAL CONTRACTOR SHALL WIRE TELEPHONE OUTLET DWELLING UNIT CLOSET.
 4. THE ELECTRICAL CONTRACTOR SHALL WIRE DWELLING UNIT TELEPHONE CABINET TO TELEPHONE BACKBOARD LOCATED IN DWELLING UNIT CLOSET.
 5. DWELLING UNIT TELEPHONE CABINET SHALL BE FINISHED AND WIRE AS SHOWN ON SHEET E-1, VERSION 03/14/07.
 6. THE ELECTRICAL CONTRACTOR SHALL FINISH AND INSTALL 1/2" CONDUIT WITH PULL ROPE TO CABLE TELEVISION POLE LOCATED IN DWELLING UNIT CLOSET.
 7. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL TELEPHONE SYSTEMS, THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR WIREWORKING ALL TELEVISIONS.
 8. 4" CONDUIT WITH PULL ROPE TO CABLE TELEVISION POLE LOCATED IN DWELLING UNIT CLOSET SHALL BE RESPONSIBLE FOR CABLE TELEVISION SYSTEMS BETWEEN THE STREET AND THE BUILDING MAIN CAVITY EQUIPMENT.
 9. THE GENERAL CONTRACTOR SHALL FINISH AND INSTALL 3/4" X 4" X 4'-0" CABLE TELEVISION SYSTEM PLYWOOD BACKBOARD FOR TELEVISION EQUIPMENT.
 10. THE ELECTRICAL CONTRACTOR SHALL FINISH AND INSTALL CABLE TELEVISION SYSTEM WIRING BETWEEN DWELLING UNIT FLOOR, CABLE SHALL MEET THE REQUIREMENTS OF THE LOCAL ELECTRICAL CODES AND THE BUILDING MAIN CAVITY EQUIPMENT SHALL BE INSTALLED IN A 1" CONDUIT.
 11. THE ELECTRICAL CONTRACTOR SHALL FINISH AND INSTALL CABLE TELEVISION SYSTEM WIRING BETWEEN THE DWELLING UNIT TELEVISION SPLITTER CABLE SHALL MEET THE REQUIREMENTS OF CONNECTION SHALL BE BY THE LOCAL CABLE TELEVISION SYSTEM SUPPLIER.
 12. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL SLEEVES AND WIREWORKING FOR CABLE TELEVISION SYSTEMS AND PRESSURE OF PENETRATION OF CAVITY SYSTEM AND PRESSURE OF PENETRATION OF CAVITY SYSTEM SHALL BE INSTALLED IN A 1" CONDUIT WITH AN GROUND TO THE BUILDING WATER SOURCE.
 13. THE ELECTRICAL CONTRACTOR SHALL FINISH AND INSTALL 1/2" CONDUIT WITH AN GROUND TO THE BUILDING WATER SOURCE.